

A2O Biological Pool Calculator

| Process Calculation | | | | | |
|--|---|---------------------|---|-----------------------|---------------------------------------|
| Design Parameter | | | | | |
| serial number | item | symbol | formula | calculated value | unit |
| (一) | Water intake | | | | |
| 1 | Engineering design scale | Q ₀ | | 7000 | m ³ /d |
| 2 | Coefficient of total change | K _T | | 1.15 | |
| 3 | Average daily, average hourly flow | Q ₀ | Q ₀ /24 | 291.666667 | m ³ /h |
| 4 | Maximum daily and hourly flow | Q _{max} | Q ₀ /3600 | 0.081018519 | m ³ /s |
| 5 | | Q _{max} | Q ₀ *K _T | 428.75 | m ³ /h |
| 6 | | Q _{max} | Q ₀ /3600 | 0.119097222 | m ³ /s |
| (二) | Influent and Effluent Water Quality | | | | |
| Water quality parameter | Water intake index (mg/L) | symbol | Influent Standards (mg/L) | symbol | Removal rate% |
| COD _{Cr} | 400 | COD _{Cr} | 50 | COD _{Cr} | 87.5 |
| BOD ₅ | 120 | S ₀ | 10 | S ₀ | 91.6666667 |
| TSS | 220 | TSS | 10 | TSS | 95.45454545 |
| NH ₃ -N | 25 | N ₀ | 5 | N ₀ | 80 |
| TN | 35 | N _T | 5 | N _T | 85.71428571 |
| NO ₃ -N | 0 | N ₃ | 15 | N ₃ | 57.14285714 |
| TP | 3 | P ₀ | 0.5 | P ₀ | 83.33333333 |
| PH | 6~9 | | | | |
| 碱度 | 280 | S _{Ca} | | | |
| T _{max} | 20 | ℃ | | | |
| T _{min} | 14 | ℃ | | | |
| (三) | A⁰ Biological pool (Anaerobic/Anoxic/Aerobic) | | | | |
| Determine whether the A ⁰ process can be used | | | | | |
| 1 | BOD ₅ /TN (Carbon to Nitrogen Ratio) | k ₁ | S ₀ /N ₀ | 3.428571429 | >4 |
| 2 | BOD ₅ /TP (Carbon to Phosphorus Ratio) | k ₂ | S ₀ /P ₀ | 40 | >17 |
| (二) | A⁰ Biological pool values calculated (Sludge Loading Rate Method) | | | | |
| BOD ₅ , N and P were removed from the water | | | | | |
| 1 | A ⁰ Biological pool volume | Q ₀ | Q ₀ | 7000 | m ³ /d |
| 2 | BOD ₅ Sludge Loading | N ₀ | N ₀ | 0.08 | kgBOD ₅ /(kgMLSS·d) |
| 3 | Mixed liquid suspension solid concentration | X ₀ | X ₀ | 3500 | mgMLSS/L |
| 4 | Sludge backflow ratio | R ₀ | R ₀ | 1 | 100% backflow |
| 5 | Denitrification Rate | η ₁ | N ₀ -N ₃ /N ₀ | 0.571428571 | 60% 85% |
| 6 | Mixed liquid backflow ratio | R ₀ | η ₁ / (1-η ₁) | 1.333333333 | 100% 400% |
| 7 | Effective volume of A ⁰ Biological res. | V ₀ | Q ₀ (S ₀ - S ₀) / NX | 2750 | m ³ |
| 8 | Total residence time of A ⁰ Biological res. | HRT ₀ | V ₀ / Q ₀ | 0.392857143 | d |
| 9 | The ratio of Anaerobic/Anoxic/Aerobic res. | k ₁ | 24 × HRT ₀ | 9.428571429 | h |
| 10 | Anaerobic zone residence time | HRT ₁ | HRT ₀ / (1+2+8) | 0.857142857 | h |
| 11 | Anoxic zone residence time | HRT ₂ | HRT ₀ / (1+2+8) | 1.714285714 | h |
| 12 | Aerobic zone residence time | HRT ₃ | HRT ₀ / (1+2+8) | 6.857142857 | h |
| 13 | Anaerobic zone effective volume | V ₀₁ | V ₀ / (1+2+8) | 250 | m ³ |
| 14 | Anoxic zone effective volume | V ₀₂ | V ₀ / (1+2+8) | 500 | m ³ |
| 15 | Aerobic zone effective volume | V ₀₃ | V ₀ / (1+2+8) | 2000 | m ³ |
| (三) | k Nitrogen and Phosphorus load | | | | |
| 1 | Total nitrogen load in aerobic sec. | k _N | Q ₀ N ₃ / X ₀ V ₀₃ | 0.035 | kgTN/(kgMLSS·d) |
| 2 | Total phosphorus load in anaerobic sec. | k _P | Q ₀ P ₀ / X ₀ V ₀₁ | 0.024 | kgTP/(kgMLSS·d) |
| (四) | Calculation of residual sludge volume | | | | |
| 1 | Total sludge yield (increase) | Y | Y | 0.6 | kgMLSS/kgBOD ₅ |
| 2 | The proportion of MLVSS in MLSS | f | f | 0.7 | kgMLVSS/kgMLSS |
| 3 | Endogenous Metabolism | k _d | k _d | 0.05 | d ⁻¹ |
| 4 | Biomass Yield | P ₀ | YQ(S ₀ -S ₀) - k _d VX | 125.125 | g/d |
| 5 | Inorganic Sludge Yield | P _{0i} | Q(T _{SS} -T _S) × 50%/1000 | 735 | kg/d |
| 6 | Residual Sludge Yield | ΔX ₀ | P ₀ +P _{0i} | 860.125 | kg/d |
| (五) | Alkalinity Verification | | | | |
| 1 | Nitrogen Content in Activated Sludge | k _N | k _N | 0.124 | |
| 2 | Daily Microbial Assimilatory Nitrogen Requirement | N ₀ | P ₀ × k _N | 15.5195 | kg/d |
| 3 | The amount of NH ₃ -N that has been oxidized | N ₀ | N ₀ × 1000 / Q ₀ | 2.2165 | mgNH ₃ -N/L |
| 4 | Amount of denitrification required | N ₀ | N ₀ -N ₃ -N ₀ | 27.7835 | mgNH ₃ -N/L |
| 5 | The amount of nitrate nitrogen that needs to be reduced | N ₀ | N ₀ -N ₃ -N ₀ | 17.7835 | mgNO ₃ -N/d |
| 6 | The oxidation of 1mgNH ₃ -N consumes alkali | S _{0,alk} | Q(S ₀ -S ₀) × 7.14 | 198.37419 | mg/L |
| 7 | Oxidizing NH ₃ -N consumes total alkali | S _{0,alk} | S _{0,alk} × N ₀ | 198.37419 | mg/L |
| 8 | Removal of 1mgBOD ₅ produces alkali | S _{0,alk} | S _{0,alk} | 0.1 | mg/mgBOD ₅ |
| 9 | Remove the total alkalinity produced | S _{0,alk} | S _{0,alk} × (S ₀ -S ₀) | 11 | mg/L |
| 10 | Reduction of 1mgNO ₃ -N produces alkali | S _{0,alk} | S _{0,alk} | 3.57 | mg/mgNO ₃ -N |
| 11 | Reduction of NO ₃ -N produces total alkali | S _{0,alk} | S _{0,alk} × N ₀ | 63.487095 | mg/L |
| 12 | Residual alkalinity | S _{0,alk} | S _{0,alk} × S ₀ + S _{0,alk} × S ₀ + S _{0,alk} × S ₀ | 156.112905 | mg/L |
| (六) | Size calculated of A2O Biological reaction tank | | | | |
| 1 | number of reaction tank | n | n | 3 | 组 |
| 2 | Single reaction tank capacity | V ₀ | V ₀ /n | 1375 | m ³ |
| 3 | Effective water depth of single reaction tank | H | H | 9 | m |
| 4 | Effective area of single reaction tank | S ₀ | V ₀ /H | 275 | m ² |
| 5 | The number of corridors of a single push | n ₁ | n ₁ | 2 | 个 |
| 6 | Gallery width | B | B | 9 | m |
| 7 | Width of single reaction cell | W | B × n ₁ | 18 | m |
| 8 | Length of a single reaction pool | L | S ₀ /W | 15.27777778 | m |
| 9 | Check the width to depth ratio | k ₁ | B/H | 1.8 | 1~2 |
| 10 | Check the aspect ratio | k ₂ | L/B | 6.944444444 | 5~10 |
| 11 | Reaction tank super-elevation | H ₁ | H ₁ | 0.5 | 0.5~1.0m |
| 12 | Total reaction tank height | H ₂ | H+H ₁ | 5.5 | m |
| (七) | Calculation of inlet and outlet pipes in reaction tank | | | | |
| 1 | Design flow of the main inlet pipe of the reaction tank | Q ₀ | Q ₀ | 0.081018519 | m ³ /s |
| 2 | Inlet pipe velocity | v ₁ | v ₁ | 0.3 | m/s |
| 3 | Cross-sectional area of water inlet | S ₁ | Q ₀ /v ₁ | 0.101273148 | m ² |
| 4 | Inlet pipe diameter | D ₁ | √(4S ₁ /π) | 0.359089097 | m |
| 5 | Check pipe flow rate | v ₁ | Q ₀ / (π/4 × D ₁ ²) | 0.286544398 | m/s |
| 6 | Design flow of return sludge pipe | Q ₀ | R × Q ₀ | 0.081018519 | m ³ /s |
| 7 | Flow rate of return sludge pipe | v ₂ | v ₂ | 0.3 | m/s |
| 8 | Cross-sectional area of return sludge pipe | S ₂ | Q ₀ /v ₂ | 0.101273148 | m ² |
| 9 | Diameter of return sludge pipe | D ₂ | √(4S ₂ /π) | 0.359089097 | m |
| 10 | Design flow of inlet hole of a single biological reaction tank | Q ₀ | (1+R) Q ₀ /n | 0.081018519 | m ³ /s |
| 11 | Inlet velocity | v ₃ | v ₃ | 0.4 | m/s |
| 12 | Water inlet crossing area | A ₁ | Q ₀ /v ₃ | 0.135030854 | m ² |
| 13 | Long side of water inlet hole | L ₁ | √A ₁ | 0.36746546 | m |
| 14 | Weir discharge | Q ₀ | (1+R) Q ₀ /n | 0.162037037 | m ³ /s |
| 15 | Outlet weir width | B ₀ | B ₀ | 9 | m |
| 16 | The water head above the weir | H ₀ | H ₀ | 0.093 | m |
| 17 | Flow coefficient | m | 0.405 × 0.0027 / H ₀ | 0.43753012 | |
| 18 | Weir discharge | Q ₀ | m B ₀ √(2gH ₀) ^{3/2} | 0.41707783 | m ³ /s |
| 19 | Discharge rate of water outlet | Q ₀ | Q ₀ | 0.162037037 | m ³ /s |
| 20 | Outlet flow rate | v ₃ | v ₃ | 0.6 | m/s |
| 21 | Water outlet area | A ₀ | Q ₀ /v ₃ | 0.270061728 | m ² |
| 22 | Outlet hole side length | L ₀ | √A ₀ | 0.519674637 | m |
| 23 | Design flow of outlet pipe | Q ₀ | Q ₀ | 0.162037037 | m ³ /s |
| 24 | Flow rate of outlet pipe | v ₄ | v ₄ | 0.3 | m/s |
| 25 | Cross-sectional area of outlet pipe | S ₀ | Q ₀ /v ₄ | 0.202546296 | m ² |
| 26 | Outlet pipe diameter | D ₀ | √(4S ₀ /π) | 0.50782867 | m |
| 27 | Check pipe flow rate | v ₄ | Q ₀ / (π/4 × D ₀ ²) | 0.322362448 | m/s |
| (八) | Aeration system design and calculation | | | | |
| 1 | BOD ₅ decomposition rate constant | k ₁ | k ₁ | 0.23 | d ⁻¹ |
| 2 | BOD ₅ test time | t ₅ | t ₅ | 5 | d |
| 3 | Remove BOD ₅ oxygen demand | D ₀₁ | Q(S ₀ -S ₀) / (1-e ^{-k₁t₅}) | 1126.77969 | kgO ₂ /d |
| 4 | BOD oxygen equivalent in residual sludge | D ₀₂ | 1.42 × P ₀ | 177.6775 | kgO ₂ /d |
| 5 | Carbon oxygen demand | D ₀₃ | D ₀₁ +D ₀₂ | 949.1024693 | kgO ₂ /d |
| 6 | Removing NH ₃ -N oxygen demand | D ₀₄ | 4.6Q(N ₀ -N ₃)/1000 | 966 | kgO ₂ /d |
| 7 | Residual sludge NH ₃ -N oxygen demand | D ₀₅ | 4.6 × 12.4N ₀ /1000 | 71.3713 | kgO ₂ /d |
| 8 | Nitrifying oxygen demand | D ₀₆ | D ₀₄ +D ₀₅ | 894.6287 | kgO ₂ /d |
| 9 | Nitrogen removal by nitrification | D ₀₇ | 2.86 × N ₀ | 356.02567 | kgO ₂ /d |
| 10 | Actual total average oxygen | AOR ₀ | D ₀₃ +D ₀₆ -D ₀₇ | 1487.705499 | kgO ₂ /h |
| 11 | Actual total maximum oxygen | AOR _{0max} | AOR ₀ /24 | 61.98772914 | kgO ₂ /h |
| 12 | Actual total maximum oxygen | AOR _{0max} | 1.4 × AOR ₀ | 2082.787699 | kgO ₂ /h |
| 13 | Remove 1kgBOD ₅ oxygen demand | AOR _{0max} | AOR _{0max} /24 | 86.78282079 | kgO ₂ /h |
| 14 | Water dissolved oxygen saturation | C _{0,20} | Q(S ₀ -S ₀) / (Q(S ₀ -S ₀)) | 1.932085064 | kgO ₂ /kgBOD |
| 15 | TC water dissolved oxygen saturation | C _{0,15} | C _{0,20} | 9.17 | mg/L |
| 16 | Standard atmosphere | P ₀ | P ₀ | 101300 | Pa |
| 17 | Pressure correction factor | ρ | ρ | 1 | |
| 18 | Concentration of dissolved oxygen | C ₀ | C ₀ | 2 | mg/L |
| 19 | Ratio of oxygen transfer rate | α | α | 0.82 | |
| 20 | Ratio of saturated dissolved oxygen | β | β | 0.95 | |
| 21 | Microporous aerator from the installation depth | H ₀ | H ₀ | 0.2 | m |
| 22 | Pressure at the outlet of aerator | P ₀ | P ₀ | 9800 × H ₀ | Pa |
| 23 | Oxygen transfer efficiency of aerator | E _a | E _a | 0.2 | |
| 24 | The percentage of oxygen when the air leaves the pool | O ₁ | 21(1-E _a) / (79+21(1-E _a)) | 0.175365344 | |
| 25 | Aerobic tank dissolved oxygen concentration | C _{0,15} | C ₀ / (1 - O ₁) | 11.54846563 | mg/L |
| 26 | Aerobic tank standard state total average oxygen demand | SOR ₀ | AOR ₀ × C _{0,15} / (α × β × C _{0,15} - C ₀) × 1.024 ³⁻²⁰ | 2138.106259 | kgO ₂ /d |
| 27 | Aerobic pool standard state average hourly capacity of | G ₀ | SOR ₀ /24 | 89.0877608 | kgO ₂ /h |
| 28 | Average hourly capacity of a | G ₀ | G ₀ /60 | 1.484796013 | m ³ /h |
| 29 | Aerobic tank maximum hourly capacity of a | G _{0max} | G ₀ /60 | 24.74660022 | m ³ /min |
| 30 | Maximum hourly capacity of a | G _{0max} | G ₀ /60 | 12.37330011 | m ³ /min |
| 31 | Gas supply per m ³ of sewage | G ₀ | 24 × G ₀ /Q ₀ | 5.090729188 | m ³ /m ³ sewage |
| 32 | Resistance of air supply | R ₀ | R ₀ | 0.051 | MPa |
| 33 | Local resistance of air | R ₀ | R ₀ | 0.001 | MPa |
| 34 | Aerator flooding head | R ₀ | 0.01 × (H-H ₀) | 0.048 | MPa |
| 35 | Aerator resistance | R ₀ | R ₀ | 0.004 | MPa |
| 36 | Required water head | ΔH ₀ | ΔH ₀ | 0.005 | MPa |
| 37 | Required wind pressure in | P ₀ | P ₀ | 0.059 | MPa |
| 38 | Individual aerator | q ₀ | q ₀ | 59 | kgPa |
| 39 | Single aerator service area | S ₀ | S ₀ | 0.2075 | m ² /h |
| 40 | The number of aerators in one | n ₁ | G _{0max} /q ₀ | 519.6786047 | pcs |
| 41 | Surface area of a single | F ₀ | F ₀ | 200 | m ² |
| 42 | Single cell aerator service area | F ₀ | F ₀ /n ₁ | 0.38485325 | m ² |
| 43 | Wind speed of the branch pipe | v ₀ | v ₀ | 10 | m/s |
| 44 | Air drying pipe diameter | d ₀ | √(4G _{0max} /πv ₀) | 0.271144767 | m |
| 45 | The air volume of the branch | G _{0max} | G _{0max} /n ₁ | 0.144355168 | m ³ /s |
| 46 | Both sides of the air supply branch pipe diameter | d ₀ | √(4G _{0max} /πv ₀) | 0.135722383 | m |
| (九) | Anoxic tank stirring equipment calculation | | | | |
| 1 | Number of anoxic pool groups | n ₁ | n ₁ | 2 | group |
| 2 | Single anoxic pool volume | V ₀ | V ₀ /n ₁ | 250 | m ³ |
| 3 | Each m ³ sewage mixing power required | P ₀ | P ₀ | 2 | kw |
| 4 | Stirring power required for a | P ₀ | P ₀ × V ₀ | 1.25 | kw |
| (十) | | | | | |